

**Office of the
Executive Engineer, Electrical Inspectorate, Haryana,
Zone-1, Near Bakhtawar Bhawan, Police Chowki Wali Gali, Jharsa
Gurugram (e-mail: xenceiggn@gmail.com).**

To

M/s Salwan Public School
Sector-15, Part-II,
Gurugram.

Application No. 7218-1599

Dated: 03/08/2024

Memo No: H.T.I/ 10835


Dated: 6/8/2024

Subject: Annual inspection of installation comprising of 1x400 KVA T/F & 1x250 KVA, 1x125 KVA D.G Sets under Rule Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010 for the year 2024-25 (from August 2024 to July 2025)

The subject cited installation was inspected by this department and the same was found generally complying with the relevant provisions of CEA (Measures Relating to Safety and Electric Supply) Regulations, 2010. However you are advised to set right the loose & temporary wiring/joints and install ELCB in light circuit.

Consistent compliance of the relevant provisions of CEA Regulations, 2010 be ensured in the installation at your end and the electrical installation be maintain and operated in a condition free from danger and as recommended by the manufacturer or by the relevant code of practice of the Bureau of Indian Standards.

You are further advised to install the smart meter to read the energy generated and send the monthly statement of the units generated from your DG Sets to this department. **Note:- 1. It is advised that running of D.G sets is without prejudice to Government terms and condition/Regulation & Norms.**


Executive Engineer
Electrical Inspectorate, Haryana,
Zone-1, Gurugram